



Remarques: -----

Consommation :	Total STEP	182'598 kWh
Consommation externe	83'543 kWh	
Consommation haut tarif	56'210 kWh	
Consommation bas tarif	27'333 kWh	
Pointe		
Energie réactive	14'476 kVarh	

Proportion Energie/ EH	0.14 kWh/EH
Proportion Energie/volume	0.46 kWh/m3
Proportion Energie/charge	0.93 kWh/kg O2 de DCO



Consommation interne: 99'055 kWh

